

# VOC Content Test Certificate

Thursday 17<sup>th</sup> December 2020

Supplier: Parchem Construction Supplies Pty Ltd (7 Lucca Rd, Wyong, NSW 2259, Australia)

Product Description: Fosroc® Nitoflor® PU200

Date Tested: December 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings Materials. ASTM D3960 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

**Test Data:**


<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>Fosroc® Nitoflor®</b>  <b>PU200</b>
<b>One and Two Pack Performance Coatings for Floors:</b> <b>140 grams per Liter</b>	<b>49 grams per Liter as VOC content</b> <b>per material</b>
<p><i>We hereby certify that Fosroc® Nitoflor® PU200 is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys  
PhD, BSc (Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BEng (Chem. Eng.)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant

V2012002A