Email: producttesting@awgc.com.au



FINAL REPORT

Internet: www.awgc.com.au

310866 Report ID:

Report Information

Submitting Organisation: 00109358: Parchem Construction Supplies Pty Ltd

Account: 130335 : Parchem Construction Supplies Ptv Ltd

AWQC Reference: 130335-2020-CSR-17: Prod Test: Fosroc Renderoc LA55

PT-4522 **Project Reference:**

Fosroc Renderoc LA55 **Product Designation:**

Cementitious. **Composition of Product:**

Parchem Construction Supplies, Wyong, NSW, AUSTRALIA. **Product Manufacturer:**

Use of Product: In-Line/Free Flowing Cementitious Repair Mortar.

As provided by the submitting organisation. Sample Selection:

AS/NZS 4020 TESTING OF PRODUCTS FOR USE IN CONTACT WITH DRINKING **Testing Requested:**

WATER

Composite **Product Type:**

Samples were prepared and controlled as described in Appendix A of AS/NZS 4020:2018 Samples:

Extracts: Extracts were prepared as described in Appendix/Clause C, D, E, F, G, H, 6.8.

Project Completion Date: 08-Jun-2021

Product sample received in the week 07-Dec-2020 and testing commenced 01-Feb-2021. **Project Comment:**

PLEASE NOTE THAT THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL

THE RESULTS STATED IN THIS REPORT RELATE TO THE SAMPLE OF THE PRODUCT SUBMITTED FOR TESTING. ANY CHANGES IN THE MATERIAL FORMULATION, PROCESS OF MANUFACTURE, THE METHOD OF APPLICATION, OR THE SURFACE AREA-TO-VOLUME RATIO IN THE END USE, COULD AFFECT THE SUITABILITY OF THE PRODUCT FOR USE IN CONTACT WITH DRINKING WATER

Marion

Michael Glasson APPROVED SIGNATORY



Corporate Accreditation No.1115 Chemical and Biological Testing Accredited for compliance with ISO/IEC 17025





Internet: www.awqc.com.au Email: producttesting@awqc.com.au

FINAL REPORT

Report ID: 310866

Summary of Results

APPENDIX/CLAUSE	RESULTS
C - Taste	Passed at an exposure of 15000 mm² per Litre.
D - Appearance	Passed at an exposure of 15000 mm² per Litre.
E - Growth of Aquatic Micro-organisms	Passed at an exposure of 15000 mm² per Litre.
F — Cytotoxic Activity	Passed at an exposure of 15000 mm² per Litre.
G - Mutagenic Activity	Passed at an exposure of 15000 mm² per Litre.
H - Metals	Passed at an exposure of 15000 mm² per Litre.
6.8 — Organic Compounds	Passed at an exposure of 15000 mm² per Litre.

Test Methods

Test(s) in Appendix	AWQC Test Method	Reference Method
С	T0320-01	AS/NZS 4020:2018
D	TO029-01 & TO018-01	APHA 2120c & APHA 2130b
E	TO014-03	APHA 4500 O G
F	TM-001	AS/NZS 4020:2018
G	TM-002	AS/NZS 4020:2018
Н	TIC-006	EPA 200.8

Organic Test Methods

Test(s) in Clause	Test Method	Reference Method
Clause 6.8	TMZ-M36 USEPA524.2	
	EP239	USEPA521
	EP132-LL USEPA_SW846-8270D	
	EP075C	USEPA_SW846-8270D
	EP075ASIM USEPA_SW846-8270D	

Summary Comment:

Compound was applied (to glass slides) at a ratio of 2.8 Litres of water to 20kg of Renderoc LA55. Ten sequential soakings were performed to obtain a pH < 9.0. In accordance with section A8 (Cementitious Products).



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance with ISO/IEC 17025



Email: producttesting@awgc.com.au

AWQC

Internet: www.awgc.com.au

FINAL REPORT

Report ID: 310866

CLAUSE 6.2 Taste

Sample Description The sample consisted of two coated panels (each coated to one side) with dimensions 75

mm x 100 mm and providing a total surface area of approximately 15000 mm²/L. Extracts

were prepared using 1000 mL volumes of pre-conditoning water(Al 12.6).

Extraction Temperature 20°C ± 2°C.

Test Method Taste (Appendix C)

Test Information

Scaling Factor Not applicable.

Results Not detected (sample and controls).

Evaluation The product passed the requirements of clause 6.2 when tested at an exposure of 15000 mm

² per Litre.

Number of Samples 2.

Test Comment The 24 hour extracts not analysed in this test.

All Mary

Peter Christopoulos
APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance with ISO/IEC 17025



Email: producttesting@awgc.com.au

Internet: www.awgc.com.au

FINAL REPORT

310866 Report ID:

CLAUSE 6.3 Appearance

Sample Description The sample consisted of two coated panels (each coated to one side) with dimensions 75

mm x 100 mm and providing a total surface area of approximately 15000 mm²/L. Extracts

were prepared using 1000 mL volumes of pre-conditoning water(Al 12.6).

20°C ± 2°C. **Extraction Temperature**

Test Method Appearance (Appendix D)

Scaling Factor Not applicable.

Results

	Test (- Blank)	Maximum Allowed	<u>Units</u>
Colour	<1	5	HU
Turbidity	<0.1	0.5	NTU

Evaluation The product passed the requirements of clause 6.3 when tested at an exposure of 15000 mm

² per Litre.

1. **Number of Samples**

Test Comment Not applicable.

ndrew Paul Ford Andrew Ford

APPROVED SIGNATORY



Corporate Accreditation No.1115 Chemical and Biological Testing Accredited for compliance with ISO/IEC 17025



AWQC

Internet: www.awqc.com.au Email: producttesting@awqc.com.au

FINAL REPORT

Report ID: 310866

CLAUSE 6.4 Growth of Aquatic Micro-organisms

Sample Description The sample consisted of two coated panels (each coated to one side) with dimensions 75

mm x 100 mm and providing a total surface area of approximately 15000 mm²/L. Extracts

were prepared using 1000 mL volumes of test water.

Test Method Growth of Aquatic Micro-organisms (Appendix E)

Inoculum The volume of the inoculum was 100 mL

Scaling Factor Not applicable.

Results

Mean Dissolved Oxygen Control 6.5 mg/L

Mean Dissolved Oxygen Difference Positive Reference 3.1 mg/L

Negative Reference <0.1 mg/L

Test <0.10 mg/L

Evaluation The product passed the requirements of clause 6.4 when tested at an exposure of 15000 mm

² per Litre.

Number of Samples 1.

Test Comment Not applicable.

Thuy Diep
APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance with ISO/IEC 17025

Elwa



Email: producttesting@awqc.com.au



Internet: www.awqc.com.au

FINAL REPORT

Report ID: 310866

CLAUSE 6.5 Cytotoxic Activity

Sample Description The sample consisted of two coated panels (each coated to one side) with dimensions 75

mm x 100 mm and providing a total surface area of approximately 15000 mm²/L. Extracts

were prepared using 1000 mL volumes of pre-conditoning water(Al 12.6).

Extraction Temperature $20^{\circ}\text{C} \pm 2^{\circ}\text{C}$.

Test Method Cytotoxic Activity (Appendix F)

Scaling Factor Not applicable.

Results Non-Cytotoxic (sample and controls).

Evaluation The product passed the requirements of clause 6.5 when tested at an exposure of 15000 mm

² per Litre.

Number of Samples 1.

subsequently used to grow a cell line (ATCC Number CCL 81) in the analysis. In addition

zinc sulphate (0.4 mmol) was used for the positive control in the analysis.



Mira Maric

APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance with ISO/IEC 17025





Internet: www.awqc.com.au Email: producttesting@awqc.com.au

FINAL REPORT

Report ID: 310866

CLAUSE 6.6 Mutagenic Activity

Sample Description The sample consisted of two coated panels (each coated to one side) with dimensions 75

mm x 100 mm and providing a total surface area of approximately 15000 mm²/L. Extracts

were prepared using 1000 mL volumes of pre-conditoning water(Al 12.6).

Extraction Temperature 20°C ± 2°C.

Test Method Mutagenic Activity (Appendix G)

Scaling Factor Not applicable.

Results

Bacteria Strain Number of Revertants per Plate

Salmonella typhimurium TA98 Mean ± Standard deviation	S9 -	Blank 18, 20, 24 20.7 ± 3.1	Sample Extract 24, 16, 21 20.3 ± 4.0	Positive Controls 3773, 4169, 3956 3966.0 ± 198.2	<u>NPD (</u> 20μg)
Mean ± Standard deviation	+	21, 30, 22 24.3 ± 4.9	21, 20, 22 21.0 ± 1.0	3397, 3472, 3489 3452.7 ± 49.0	<u>2-AF (</u> 20μg)
Salmonella typhimurium TA102 Mean ± Standard deviation	-	401, 444, 413 419.3 ± 22.2	381, 399, 413 397.7 ± 16.0	4424, 3678, 3316 3806.0 ± 565.0	<u>Mitomycin C(</u> 10μg)
Mean ± Standard deviation	+	536, 528, 411 491.7 ± 70.0	525, 487, 465 492.3 ± 30.4	2436, 2670, 2582 2562.7 ± 118.2	

Comments S9 was used as the metabolic activator. NPD (4-nitro-o-phenylenediamine) and Mitomycin

C are specific positive controls for strains TA98 - and TA102 (- and +) respectively, while 2-AF (2-aminofluorene) when used in conjunction with S9 is a positive control for TA98+.

Evaluation The product passed the requirements of clause 6.6 when tested at an exposure of 15000 mm

² per Litre.

Number of Samples 1.

Test CommentThe differences in the mean number of revertants between the blank and test extracts do not

exceed two standard deviations; accordingly there is no evidence of a mutagenic response.

Peter Christopoulos
APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance with ISO/IEC 17025



ABN 69336525019 SAW_PT_Final_2018.RPT

Page 7 of 12

ctoria Square Tel: 1300 653 366 de SA 5000 Fax: 1300 883 171

Email: producttesting@awgc.com.au



FINAL REPORT

Internet: www.awgc.com.au

Report ID: 310866

CLAUSE 6.7 Metals

Sample Description The sample consisted of two coated panels (each coated to one side) with dimensions 75

mm x 100 mm and providing a total surface area of approximately 15000 mm²/L. Extracts

were prepared using 1000 mL volumes of pre-conditoning water(Al 12.6).

Extraction Temperature 20°C ± 2°C.

Test Method Metals (Appendix H)

Scaling Factor Not applicable.

Method of Analysis All methods used to determine concentrations of metals are based on those described in

the US EPA method 200.8 Determination of Trace elements in Waters and Wastes by Inductively Coupled Plasma - Mass Spectrometry. The methods have been adapted for the

instrumentation in use at the Australian Water Quality Centre.

Concentration of the metals described in Table 2 of the AS/NZS 4020:2018 are determined

as follows:

Aluminium, Antimony, Arsenic, Barium, Boron, Cadmium, Chromium, Copper, Iron, Lead, Manganese, Mercury, Molybdenum, Nickel, Selenium and Silver by Inductively Coupled

Plasma Mass Spectrometry.

Results	Limit of Reporting	Blank	Test 1	Test 2	Max Allowed
	mg/L	mg/L	mg/L	mg/L	mg/L
Final Extract					
Aluminium	0.001	0.019	0.029	0.029	0.2
Antimony	0.0005	<0.0005	<0.0005	<0.0005	0.003
Arsenic	0.0003	<0.0003	< 0.0003	< 0.0003	0.01
Barium	0.0005	0.0263	0.0287	0.0274	0.7
Boron	0.020	<0.020	<0.020	<0.020	1.4
Cadmium	0.0001	<0.0001	<0.0001	<0.0001	0.002
Chromium	0.0001	0.0002	0.0002	0.0002	0.05
Copper	0.0001	0.0651	0.0707	0.0661	2.0
Iron	0.0005	0.0091	0.0079	0.0088	0.3
Lead	0.0001	0.0003	0.0005	0.0005	0.01
Manganese	0.0001	0.0015	0.0015	0.0016	0.1
Mercury	0.00003	<0.00003	<0.00003	<0.00003	0.001
Molybdenum	0.0001	0.0002	0.0002	0.0001	0.05
Nickel	0.0001	0.0007	0.0009	0.0008	0.02
Selenium	0.0001	<0.0001	<0.0001	<0.0001	0.01
Silver	0.00003	<0.00003	< 0.00003	< 0.00003	0.1

Evaluation The product passed the requirements of clause 6.7 when tested at an exposure of 42000 mm

² per Litre.

Number of Samples 1.

Test Comment Not applicable.

Dzung Bui APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance with ISO/IEC 17025



ABN 69336525019 SAW PT Final 2018.RPT

Page 8 of 12

AWQC

Internet: www.awqc.com.au Email: producttesting@awqc.com.au

FINAL REPORT

Report ID: 310866

CLAUSE 6.8 Organic Compounds

Sample Description The sample consisted of two coated panels (each coated to one side) with dimensions 75 mm

x 100 mm and providing a total surface area of approximately 15000 mm²/L. Extracts were

prepared using 1000 mL volumes of pre-conditoning water(Al 12.6).

Extraction Temperature $20^{\circ}\text{C} \pm 2^{\circ}\text{C}$.

Test Method Organic Compounds (Clause 6.8). Max Allowed values are taken from the Australian Drinking

Water Guidelines and Drinking-water Standards for New Zealand. Please note, some reported

compounds have no guideline value.

Scaling Factor Not applicable.

Results

Organic Compound

Nitrosamines	Blank	Test	Max Allowed
	μg/L	μg/L	
!External Lab Report No.	ES2104919	ES2104919	
1-Nitrosopiperidine (NPip)	<0.003	<0.003	
1-Nitrosopyrrolidine (NPyr)	<0.01	<0.01	
Nitrosomorpholine (NMor)	<0.003	<0.003	
N-Nitrosodiethylamine (NDEA)	<0.01	<0.01	
N-Nitrosodimethylamine (NDMA)	<0.003	<0.003	0.1 µg/L
N-Nitrosodi-n-propylamine (NDPA)	<0.003	<0.003	
N-Nitrosomethylethylamine (NMEA)	< 0.003	< 0.003	

Organic Compound

Organic Compound			
Phenois	Blank	Test	Max Allowed
	μg/L	μg/L	
!External Lab Report No.	ES2104918	ES2104918	
2 4 5-trichlorophenol	<1.0	<1.0	
2 4 6-trichlorophenol	<1.0	<1.0	20 μg/L
2 4-dichlorophenol	<1.0	<1.0	200 μg/L
2 4-dimethylphenol	<1.0	<1.0	
2 6-dichlorophenol	<1.0	<1.0	
2-chlorophenol	<1.0	<1.0	300 μg/L
2-nitrophenol	<1.0	<1.0	
4-chloro-3-methylphenol	<1.0	<1.0	
m+p cresol	<2.0	<2.0	
o-cresol	<1.0	<1.0	
pentachlorophenol	<2.0	<2.0	9 μg/L
phenol	<1.0	1.6	







Internet: www.awgc.com.au Email: producttesting@awqc.com.au

FINAL REPORT

310866 Report ID:

Organic	Compound	t
---------	----------	---

g			
Phthalate Esters	Blank µg/L	Test μg/L	Max Allowed
15 / 11 / 5 / 11			
!External Lab Report No.	ES2104918	ES2104918	
Bis(2-ethylhexyl) phthalate	<10	<10	10 μg/L
Butyl benzyl phthalate	<2	<2	
Di(2-ethylhexyl) adipate	<2	<2	
Diethyl phthalate	<2	<2	
Dimethyl phthalate	<2	<2	
Di-n-butyl phthalate	<2	<2	
Di-n-octyl phthalate	<2	<2	

0


Organic Compound			
Polycyclic Aromatic Hydrocarbons	Blank	Test	Max Allowed
	μg/L	μg/L	
!External Lab Report No.	ES2104918	ES2104918	
Acenaphthene	<0.02	<0.02	
Acenaphthylene	<0.02	<0.02	
Anthracene	<0.02	<0.02	
Benzo(a)anthracene	<0.02	<0.02	
Benzo(a)pyrene	<0.005	<0.005	0.01 µg/L
Benzo(a)pyrene TEQ	<0.005	<0.005	
Benzo(b+j)fluoranthene	<0.02	<0.02	
Benzo(ghi)perylene	<0.02	<0.02	
Benzo(k)fluoranthene	<0.02	<0.02	
Chrysene	<0.02	<0.02	
Dibenzo(a-h)anthracene	<0.02	<0.02	
Fluoranthene	<0.02	<0.02	
Fluorene	<0.02	<0.02	
Indeno(123-cd)pyrene	<0.02	<0.02	
Naphthalene	<0.02	<0.02	
PAH - Total	<0.005	<0.005	
Phenanthrene	<0.02	<0.02	
Pyrene	<0.02	<0.02	



ABN 69336525019



Page 10 of 12





FINAL REPORT

Internet: www.awgc.com.au

Report ID: 310866

Organic (Compound
-----------	----------

Organic Compound			
Volatile Organic Compounds GCMS	Blank	Test	Max Allowed
	μg/L	μg/L	
1 1 1 2-Tetrachloroethane	<1	<1	
1 1 1-Trichloroethane	<1	<1	
1 1 2 2-Tetrachloroethane	<1	<1	
1 1 2-Trichloroethane	<1	<1	
1 1-Dichloropropene	<1	<1	
1 2 3-Trichlorobenzene	<1	<1	
1 2 3-Trichloropropane	<1	<1	
1 2 4-Trichlorobenzene	<1	<1	
1 2 4-Trimethylbenzene	<1	<1	
1 2-Dibromo-3-chloropropane	<1	<1	1 μg/L
1 2-Dibromoethane	<1	<1	1 μg/L
1 2-Dichlorobenzene	<1	<1	1500 µg/L
1 2-Dichloroethane	<1	<1	3 μg/L
1 2-Dichloropropane	<1	<1	
1 3 5-Trimethylbenzene	<1	<1	
1 3-Dichlorobenzene	<1	<1	
1 3-Dichloropropane	<1	<1	
1 4-Dichlorobenzene	<1	<1	40 µg/L
1,1-Dichloroethane	<1	<1	
1,1-Dichloroethene	<1	<1	30 μg/L
2,2-Dichloropropane	<1	<1	
2-Chlorotoluene	<1	<1	
4-Chlorotoluene	<1	<1	
4-Isopropyltoluene	<1	<1	
Benzene	<1	<1	1 μg/L
Bromobenzene	<1	<1	
Bromochloromethane	<1	<1	
Bromodichloromethane	43	35	60 μg/L
Bromoform	9	7	100 µg/L
Bromomethane	<4	<4	
Carbon tetrachloride	<1	<1	3 μg/L
Chlorobenzene	<1	<1	300 μg/L
Chloroethane	<4	<4	
Chloroform	34	29	400 μg/L
Chloromethane	<4	<4	
cis-1 3-Dichloropropene	<1	<1	
cis-1,2-Dichloroethene	<1	<1	"
Dibromochloromethane	42	34	150 μg/L
Dibromomethane	<1	<1	
Dichlorodifluoromethane	<1	<1	
Dichloromethane	<4	<4	4 μg/L
Ethylbenzene	<1	<1	300 μg/L
Hexachlorobutadiene	<0.7	<0.7	0.7 μg/L
Isopropylbenzene	<1	<1	
m+p-Xylenes - Total	<2	<2	



Corporate Accreditation No.1115 Chemical and Biological Testing Accredited for compliance with ISO/IEC 17025





Internet: www.awqc.com.au Email: producttesting@awqc.com.au

FINAL REPORT

Report ID: 310866

Organic Compound

Volatile Organic Compounds Go	CMS Blank	Test	Max Allowed
	μg/L	μg/L	
Naphthalene	<1	<1	
n-Butylbenzene	<1	<1	
n-Propylbenzene	<1	<1	
o-Xylene	<1	<1	
sec-Butylbenzene	<1	<1	
Styrene	<1	<1	30 μg/L
tert-Butylbenzene	<1	<1	
Tetrachloroethene	<1	<1	50 μg/L
Toluene	<1	<1	800 μg/L
Total 1 2-dichloroethene	<2	<2	60 μg/L
Total 1 3-dichloropropene	<2	<2	20 μg/L
Total Trichlorobenzene	<2	<2	30 μg/L
Total Xylene	<3	<3	600 µg/L
trans-1 3-Dichloropropene	<1	<1	
trans-1,2-Dichloroethene	<1	<1	
Trichloroethene	<1	<1	
Trichlorofluoromethane	<1	<1	
Trihalomethanes - Total	128	105	250 μg/L
Vinyl chloride	<0.3	<0.3	0.3 μg/L

Evaluation The product passed the requirements of clause 6.8 when tested at an exposure of 15000 mm²

per Litre.

Number of Samples 1.

Test Comment Subcontracted testing conducted by ALS, Environmental Division, NATA accreditation no. 825

site no. 10911 and ALS Scoresby, NATA accreditation no. 992, site no. 989

Qiong Huang

APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance with ISO/IEC 17025



ABN 69336525019