



Internet: www.awqc.com.au

Email: producttesting@awqc.com.au

FINAL REPORT

Report ID : 361681

Report Information

Submitting Organisation : 00109358 : Parchem Construction Supplies Pty Ltd
Account : 130335 : Parchem Construction Supplies Pty Ltd
AWQC Reference : 130335-2022-CSR-4 : Prod Test: Fosroc Renderoc LA55 Plus
Project Reference : PT-5142
Product Designation : Fosroc Renderoc LA55 Plus
Composition of Product : Cement Based Concrete Repair Mortar.
Product Manufacturer : Parchem Construction Supplies Pty Ltd., Wyong, NSW, AUSTRALIA.
Use of Product : In-Line/Cement Based Concrete Repair Flowable Mortar.
Sample Selection: As provided by the submitting organisation.
Testing Requested : **AS/NZS 4020:2018 TESTING OF PRODUCTS FOR USE IN CONTACT WITH DRINKING WATER**
Product Type : Composite
Samples : Samples were prepared and controlled as described in Appendix A of AS/NZS 4020:2018 (Incorporating Amendment No.1)
Extracts : Extracts were prepared as described in Appendix/Clause C, D, E, F, G, H, 6.8.
Project Completion Date : 08-May-2023
Project Comment : Product sample received 19-Oct-2022, testing commenced 31-Jan-2023.

PLEASE NOTE THAT THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL

THE RESULTS STATED IN THIS REPORT RELATE TO THE SAMPLE OF THE PRODUCT SUBMITTED FOR TESTING TO AS/NZS 4020:2018. ANY CHANGES IN THE MATERIAL FORMULATION, PROCESS OF MANUFACTURE, THE METHOD OF APPLICATION, OR THE SURFACE AREA-TO-VOLUME RATIO IN THE END USE, COULD AFFECT THE SUITABILITY OF THE PRODUCT FOR USE IN CONTACT WITH DRINKING WATER



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty/>



FINAL REPORT

Report ID : 361681

Summary of Results

APPENDIX/CLAUSE	RESULTS
C – Taste	Passed at an exposure of 15000 mm ² per Litre.
D – Appearance	Passed at an exposure of 15000 mm ² per Litre.
E – Growth of Aquatic Micro-organisms	Passed at an exposure of 15000 mm ² per Litre.
F – Cytotoxic Activity	Passed at an exposure of 15000 mm ² per Litre.
G – Mutagenic Activity	Passed at an exposure of 15000 mm ² per Litre.
H – Metals	Passed at an exposure of 15000 mm ² per Litre.
6.8 – Organic Compounds	Passed at an exposure of 15000 mm ² per Litre.

Test Methods

Test(s) in Appendix	AWQC Test Method	NATA Accredited
C	T0320-01	Y
D	TO029-01 & TO018-01	Y
E	TO014-03	Y
F	TM-001	Y
G	TM-002	Y
H	TIC-006	Y

Organic Test Methods

Test(s) in Clause	Test Method	NATA Accredited
Clause 6.8	TMZ-M36	Y
	EP239	Y
	EP132-LL	Y
	EP075C	Y
	EP075ASIM	Y



Corporate Accreditation No. 1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty/>



FINAL REPORT

Report ID : 361681

Laboratory Information

Laboratory	NATA accreditation ID
Product Testing	1115
Australian Laboratory Services Pty Ltd - New South Wales	825,992
Inorganic Chemistry - Physical	1115
Protozoology	1115
Organic Chemistry	1115
Inorganic Chemistry - Metals	1115
Inorganic Chemistry - Waste Water	1115

Summary Comment : The compound was applied (to glass slides) and cured for 7 days at 20°C prior to testing (ratio of 2000g powder to 230mL of water. Ten sequential soakings performed to obtain a pH < 9.0. In accordance with section A8 (Cementitious Products).



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>



Internet: www.awqc.com.au

Email: producttesting@awqc.com.au

FINAL REPORT

Report ID : 361681

CLAUSE 6.2 Taste

Sample Description	The sample consisted of two coated panels (each coated to one side) with dimensions 75 mm x 100 mm and providing a total surface area of approximately 15000 mm ² /L. Extracts were prepared using 1000 mL volumes of pre-conditioning water(AI 12.6).
Extraction Temperature	20°C ± 2°C.
Test Method	Taste (Appendix C)
Test Information	
Scaling Factor	Not applicable.
Results	Not detected (sample and controls).
Evaluation	The product passed the requirements of clause 6.2 when tested at an exposure of 15000 mm ² per Litre.
Number of Samples	2.
Test Comment	Not applicable.

Peter Christopoulos
APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>



Internet: www.awqc.com.au

Email: producttesting@awqc.com.au

FINAL REPORT

Report ID : 361681

CLAUSE 6.3 Appearance

Sample Description The sample consisted of two coated panels (each coated to one side) with dimensions 75 mm x 100 mm and providing a total surface area of approximately 15000 mm²/L. Extracts were prepared using 1000 mL volumes of pre-conditioning water(AI 12.6).

Extraction Temperature 20°C ± 2°C.

Test Method Appearance (Appendix D)

Scaling Factor Not applicable.

Results

	<u>Test (- Blank)</u>	<u>Maximum Allowed</u>	<u>Units</u>
Colour	<1	5	HU
Turbidity	<0.1	0.5	NTU

Evaluation The product passed the requirements of clause 6.3 when tested at an exposure of 15000 mm² per Litre.

Number of Samples 1.

Test Comment Not applicable.

Andrew Ford
APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>



Internet: www.awqc.com.au

Email: producttesting@awqc.com.au

FINAL REPORT

Report ID : 361681

CLAUSE 6.4 Growth of Aquatic Micro-organisms

Sample Description	The sample consisted of two coated panels (each coated to one side) with dimensions 75 mm x 100 mm and providing a total surface area of approximately 15000 mm ² /L. Extracts were prepared using 1000 mL volumes of test water.		
Test Method	Growth of Aquatic Micro-organisms (Appendix E)		
Inoculum	The volume of the inoculum was 100 mL		
Scaling Factor	Not applicable.		
Results	Mean Dissolved Oxygen	Control	7.3 mg/L
	Mean Dissolved Oxygen Difference	Positive Reference	5.4 mg/L
		Negative Reference	0.1 mg/L
		Test	0.10 mg/L
Evaluation	The product passed the requirements of clause 6.4 when tested at an exposure of 15000 mm ² per Litre.		
Number of Samples	1.		
Test Comment	Not applicable.		

Thuy Diep
APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>



Internet: www.awqc.com.au

Email: producttesting@awqc.com.au

FINAL REPORT

Report ID : 361681

CLAUSE 6.5 Cytotoxic Activity

Sample Description The sample consisted of two coated panels (each coated to one side) with dimensions 75 mm x 100 mm and providing a total surface area of approximately 15000 mm²/L. Extracts were prepared using 1000 mL volumes of pre-conditioning water(AI 12.6).

Extraction Temperature 20°C ± 2°C.

Test Method Cytotoxic Activity (Appendix F)

Scaling Factor Not applicable.

Results

24 HR	Non-cytotoxic response, healthy cell morphology with <30% cell death
48 HR	Non-cytotoxic response, healthy cell morphology with <30% cell death
72 HR	Non-cytotoxic response, healthy cell morphology with <30% cell death

Blank Control Results Blank; non-cytotoxic response, healthy cell morphology with <30% cell death

Positive Control Results Positive control; Cytotoxic response, unhealthy cell morphology with >70% cell death

The test extracts and blank extracts were used to prepare nutrient growth medium and subsequently used to grow a cell line (ATCC Number CCL 81) in the analysis. In addition zinc sulphate (0.4 mmol) was used for the positive control in the analysis.

Evaluation The product passed the requirements of clause 6.5 when tested at an exposure of 15000 mm² per Litre.

Number of Samples 1.

Test Comment Not applicable.

Mira Maric
APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>

FINAL REPORT

Report ID : 361681

CLAUSE 6.6 Mutagenic Activity

Sample Description The sample consisted of two coated panels (each coated to one side) with dimensions 75 mm x 100 mm and providing a total surface area of approximately 15000 mm²/L. Extracts were prepared using 1000 mL volumes of pre-conditioning water(AI 12.6).

Extraction Temperature 20°C ± 2°C.

Test Method Mutagenic Activity (Appendix G)

Scaling Factor Not applicable.

Results

Bacteria Strain	Number of Revertants per Plate				
	S9	Blank	Sample Extract	Positive Controls	
<i>Salmonella typhimurium</i> TA98	-	26, 28, 33	34, 29, 30	3804, 3762, 3967	<u>NPD</u> (20µg)
Mean ± Standard deviation		29.0 ± 3.6	31.0 ± 2.6	3844.3 ± 108.3	
	+	32, 29, 35	44, 42, 37	3630, 2936, 2332	<u>2-AF</u> (20µg)
Mean ± Standard deviation		32.0 ± 3.0	41.0 ± 3.6	2966.0 ± 649.5	
<i>Salmonella typhimurium</i> TA102	-	379, 370, 376	413, 407, 388	1962, 1997, 2138	<u>Mitomycin C</u> (10µg)
Mean ± Standard deviation		375.0 ± 4.6	402.7 ± 13.1	2032.3 ± 93.2	
	+	412, 440, 438	443, 452, 444	1795, 1574, 1707	
Mean ± Standard deviation		430.0 ± 15.6	446.3 ± 4.9	1692.0 ± 111.3	

The differences in the mean number of revertants between the blank and test extracts do not exceed two standard deviations; accordingly, there is no evidence of a mutagenic response.

Comments S9 was used as the metabolic activator. NPD (4-nitro-o-phenylenediamine) and Mitomycin C are specific positive controls for strains TA98 - and TA102 (- and +) respectively, while 2-AF (2-aminofluorene) when used in conjunction with S9 is a positive control for TA98+.

Evaluation The product passed the requirements of clause 6.6 when tested at an exposure of 15000 mm² per Litre.

Number of Samples 1.

Test Comment Not applicable.

Peter Christopoulos
APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty/>

FINAL REPORT

Report ID : 361681

CLAUSE 6.7

Metals

Sample Description

The sample consisted of two coated panels (each coated to one side) with dimensions 75 mm x 100 mm and providing a total surface area of approximately 15000 mm²/L. Extracts were prepared using 1000 mL volumes of pre-conditioning water(AI 12.6).

Extraction Temperature

20°C ± 2°C.

Test Method

Metals (Appendix H)

Scaling Factor

Not applicable.

Method of Analysis

Concentration of the metals described in Table 2 of the AS/NZS 4020:2018 are determined as follows:

Aluminium, Antimony, Arsenic, Barium, Boron, Cadmium, Chromium, Copper, Iron, Lead, Manganese, Mercury, Molybdenum, Nickel, Selenium and Silver by Inductively Coupled Plasma Mass Spectrometry.

Results	Limit of Reporting mg/L	Blank mg/L	Test 1 mg/L	Test 2 mg/L	Max Allowed mg/L
Final Extract					
Aluminium	0.001	0.044	0.049	0.042	0.2
Antimony	0.0003	<0.0003	<0.0003	<0.0003	0.003
Arsenic	0.00006	0.00040	0.00044	0.00043	0.01
Barium	0.0003	0.0285	0.0270	0.0267	0.7
Boron	0.020	<0.020	0.107	0.211	1.4
Cadmium	0.0001	<0.0001	<0.0001	<0.0001	0.002
Chromium	0.0001	0.0004	<0.0001	<0.0001	0.05
Copper	0.0001	0.1811	0.1494	0.1440	2.0
Iron	0.0005	0.0076	0.0058	0.0074	0.3
Lead	0.0001	0.0006	0.0007	0.0006	0.01
Manganese	0.0001	0.0008	0.0008	0.0009	0.1
Mercury	0.00003	<0.00003	<0.00003	<0.00003	0.001
Molybdenum	0.0001	0.0003	0.0004	0.0004	0.05
Nickel	0.0002	0.0018	0.0018	0.0017	0.02
Selenium	0.0001	<0.0001	<0.0001	0.0001	0.01
Silver	0.00002	<0.00002	<0.00002	<0.00002	0.1

Evaluation

The product passed the requirements of clause 6.7 when tested at an exposure of 42000 mm² per Litre.

Number of Samples

1.

Test Comment

Not applicable.

Dzung Bui

APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>

FINAL REPORT

Report ID : 361681

CLAUSE 6.8 Organic Compounds

Sample Description The sample consisted of two coated panels (each coated to one side) with dimensions 75 mm x 100 mm and providing a total surface area of approximately 15000 mm²/L. Extracts were prepared using 1000 mL volumes of pre-conditioning water(AI 12.6).

Extraction Temperature 20°C ± 2°C.

Test Method Organic Compounds (Clause 6.8). The maximum allowed (Max Allowed) values are taken from the Australian Drinking Water Guidelines and Drinking-water Standards for New Zealand. Please note, some reported compounds have no guideline value.

Scaling Factor Not applicable.

Results

Organic Compound

Nitrosamines	Blank µg/L	Test µg/L	Max Allowed
!External Lab Report No.	ES2304640	ES2304640	
1-Nitrosopiperidine (NPip)	<0.003	<0.003	
1-Nitrosopyrrolidine (NPyr)	<0.01	<0.01	
Nitrosomorpholine (NMor)	<0.003	<0.003	
N-Nitrosodiethylamine (NDEA)	<0.01	<0.01	
N-Nitrosodimethylamine (NDMA)	<0.003	<0.003	0.1 µg/L
N-Nitrosodi-n-propylamine (NDPA)	<0.003	<0.003	
N-Nitrosomethylethylamine (NMEA)	<0.003	<0.003	

Organic Compound

Phenols	Blank µg/L	Test µg/L	Max Allowed
!External Lab Report No.	ES2304640	ES2304640	
2 4 5-trichlorophenol	<1.0	<1.0	
2 4 6-trichlorophenol	<1.0	<1.0	20 µg/L
2 4-dichlorophenol	<1.0	<1.0	200 µg/L
2 4-dimethylphenol	<1.0	<1.0	
2 6-dichlorophenol	<1.0	<1.0	
2-chlorophenol	<1.0	<1.0	300 µg/L
2-nitrophenol	<1.0	<1.0	
4-chloro-3-methylphenol	<1.0	<1.0	
m+p cresol	<2.0	<2.0	
o-cresol	<1.0	<1.0	
pentachlorophenol	<2.0	<2.0	9 µg/L
phenol	<1.0	<1.0	

Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



FINAL REPORT

Report ID : 361681

Organic Compound

Phthalate Esters	Blank µg/L	Test µg/L	Max Allowed
!External Lab Report No.	ES2304640	ES2304640	
Bis(2-ethylhexyl) phthalate	<10	<10	10 µg/L
Butyl benzyl phthalate	<2	<2	
Di(2-ethylhexyl) adipate	<2	<2	
Diethyl phthalate	<2	<2	
Dimethyl phthalate	<2	<2	
Di-n-butyl phthalate	<2	<2	
Di-n-octyl phthalate	<2	<2	

Organic Compound

Polycyclic Aromatic Hydrocarbons	Blank µg/L	Test µg/L	Max Allowed
!External Lab Report No.	ES2304640	ES2304640	
Acenaphthene	<0.02	<0.02	
Acenaphthylene	<0.02	<0.02	
Anthracene	<0.02	<0.02	
Benzo(a)anthracene	<0.02	<0.02	
Benzo(a)pyrene	<0.005	<0.005	0.01 µg/L
Benzo(a)pyrene TEQ	<0.005	<0.005	
Benzo(b+j)fluoranthene	<0.02	<0.02	
Benzo(ghi)perylene	<0.02	<0.02	
Benzo(k)fluoranthene	<0.02	<0.02	
Chrysene	<0.02	<0.02	
Dibenzo(a-h)anthracene	<0.02	<0.02	
Fluoranthene	<0.02	<0.02	
Fluorene	<0.02	<0.02	
Indeno(123-cd)pyrene	<0.02	<0.02	
Naphthalene	<0.02	<0.02	
PAH - Total	<0.005	<0.005	
Phenanthrene	<0.02	<0.02	
Pyrene	<0.02	<0.02	

Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>

FINAL REPORT


Report ID : 361681

Organic Compound

Volatile Organic Compounds GCMS	Blank µg/L	Test µg/L	Max Allowed
1 1 1 2-Tetrachloroethane	<1	<1	
1 1 1-Trichloroethane	<1	<1	
1 1 2 2-Tetrachloroethane	<1	<1	
1 1 2-Trichloroethane	<1	<1	
1 1-Dichloropropene	<1	<1	
1 2 3-Trichlorobenzene	<1	<1	
1 2 3-Trichloropropane	<1	<1	
1 2 4-Trichlorobenzene	<1	<1	
1 2 4-Trimethylbenzene	<1	<1	
1 2-Dibromo-3-chloropropane	<1	<1	1 µg/L
1 2-Dibromoethane	<1	<1	1 µg/L
1 2-Dichlorobenzene	<1	<1	1500 µg/L
1 2-Dichloroethane	<1	<1	3 µg/L
1 2-Dichloropropane	<1	<1	
1 3 5-Trimethylbenzene	<1	<1	
1 3-Dichlorobenzene	<1	<1	
1 3-Dichloropropane	<1	<1	
1 4-Dichlorobenzene	<1	<1	40 µg/L
1,1-Dichloroethane	<1	<1	
1,1-Dichloroethene	<1	<1	30 µg/L
2,2-Dichloropropane	<1	<1	
2-Chlorotoluene	<1	<1	
4-Chlorotoluene	<1	<1	
4-Isopropyltoluene	<1	<1	
Benzene	<1	<1	1 µg/L
Bromobenzene	<1	<1	
Bromochloromethane	<1	<1	
Bromodichloromethane	50	48	60 µg/L
Bromoform	6	6	100 µg/L
Bromomethane	<4	<4	
Carbon tetrachloride	<1	<1	3 µg/L
Chlorobenzene	<1	<1	300 µg/L
Chloroethane	<4	<4	
Chloroform	46	44	400 µg/L
Chloromethane	<4	<4	
cis-1 3-Dichloropropene	<1	<1	
cis-1,2-Dichloroethene	<1	<1	
Dibromochloromethane	37	36	150 µg/L
Dibromomethane	<1	<1	
Dichlorodifluoromethane	<1	<1	
Dichloromethane	<4	<4	4 µg/L
Ethylbenzene	<1	<1	300 µg/L
Hexachlorobutadiene	<0.7	<0.7	0.7 µg/L
Isopropylbenzene	<1	<1	
m+p-Xylenes - Total	<2	<2	



Corporate Accreditation No. 1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty/>



Internet: www.awqc.com.au

Email: producttesting@awqc.com.au

FINAL REPORT

Report ID : 361681

Organic Compound

Organic Compound	Blank µg/L	Test µg/L	Max Allowed
Volatile Organic Compounds GCMS			
Naphthalene	<1	<1	
n-Butylbenzene	<1	<1	
n-Propylbenzene	<1	<1	
o-Xylene	<1	<1	
sec-Butylbenzene	<1	<1	
Styrene	<1	<1	30 µg/L
tert-Butylbenzene	<1	<1	
Tetrachloroethene	<1	<1	50 µg/L
Toluene	<1	<1	800 µg/L
Total 1,2-dichloroethene	<2	<2	60 µg/L
Total 1,3-dichloropropene	<2	<2	20 µg/L
Total Trichlorobenzene	<2	<2	30 µg/L
Total Xylene	<3	<3	600 µg/L
trans-1,3-Dichloropropene	<1	<1	
trans-1,2-Dichloroethene	<1	<1	
Trichloroethene	<1	<1	
Trichlorofluoromethane	<1	<1	
Trihalomethanes - Total	139	134	250 µg/L
Vinyl chloride	<0.3	<0.3	0.3 µg/L

Evaluation The product passed the requirements of clause 6.8 when tested at an exposure of 15000 mm² per Litre.

Number of Samples 1.

Test Comment The AWQC is not NATA accredited for the following tests: Nitrosamines, Phenols, Phthalate Esters and Polycyclic Aromatic Hydrocarbons. These tests are subcontracted to testing facilities that are NATA accredited for these analyses.

Qiong Huang

APPROVED SIGNATORY



Corporate Accreditation No.1115
Chemical and Biological Testing
Accredited for compliance
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>